

RESOLUTION # 90

WHEREAS, in the interest of safety and in conformance with procedures adopted by the Washington State Association of Counties, Mason County makes periodic inspections of bridges on the County road system; and

WHEREAS, detailed analysis of the steel trusses fabricated and erected circa 1925 on the Schafer Park Bridge #207-1.30 has been completed and reveals that the basic original design and the condition of the trusses are such that the bridge cannot be certified as safe for all legal highway loads; and

WHEREAS, the trusses and the treated timber deck installed in 1965 are basically sound and being properly maintained and protected;

NOW, THEREFORE BE IT RESOLVED that the gross load on Bridge #207-1.30, Schafer Park Bridge, over the East Fork of the Satsop River be limited to 24 tons for a period of five (5) years unless this Board shall by appropriate action based upon proper certification modify or remove such restrictions.

BE IT FURTHER RESOLVED that the County Engineer shall post the said Bridge with the load limit as set forth herein. Violation of this load limit constitutes a misdemeanor in accordance with RCW 26.75.270.

DATED this 27th day of April, 1970.

BOARD OF COUNTY COMMISSIONERS  
OF MASON COUNTY, WASHINGTON

Martin Quast

William O. Hunter

John Barckman

ATTEST:

Ruth E. Boyer  
Clerk of the Board